

\*These are not all inclusive, depending on project.

Please contact the Chief Electrical Inspector if you have any questions 307-733-4732.

1. State job address, building permit number (if one currently), occupancy use, NEC code year.
2. Service or feeder Load calculations for new/remodel/addition, with new/remodel/addition one line(s).
3. Electrical Panel(s) locations, voltage, phase, and fault current calculated values.
4. Panel schedules to meet Art 408.4 A & B, i. e. locations, use, no abbreviations.
5. Electrical service load calculations to meet Art 220 part 3 or part 4.
6. Grounding detail and location of grounding electrode system, as amended by Teton County Wyoming.
7. Shown locations of receptacles, lighting, mechanical equipment, utilization equipment, processing equipment, all other equipment, plus access and workspace requirements Art 110.26.
8. Complete circuiting of all receptacles, lighting, mechanical equipment, utilization equipment, processing equipment, all other equipment, and appliances.
9. Show all exit sign and emergency lighting if required to meet Art. 700.
10. Indicate on plans, (tenants) have access to all overcurrent devices. Art 230.72 & 210.25 A & B
11. If common areas, common house panel required for all common area power. House panel to be in common area accessible to all occupants. Common equipment to be in common areas. Art 230.72 & 210.25 B
12. Show locations of special devices: AFCI, GFCI, EPCD, ETC.
13. State any Special Occupancies. Chapters 5-7, i.e. (Pools/hot tubs) or hazardous locations.
14. State any Special Equipment. Chapter 5-7 i.e., Generator, PV Solar systems, Battery, ETC.
15. Show location and type of Smoke detectors. (Residential only)

Items to be on Electrical Plans for review

MEMO



40 East Pearl Avenue  
PO Box 901  
Jackson, WY 83001

JACKSON HOLE FIRE / EMS