

# COUNTY BUILDING CODES RESOLUTION

TETON COUNTY, WYOMING

Effective July 1, 2025

## TABLE OF CONTENTS

SECTION 1. TITLE.....	p.3
SECTION 2. AUTHORITY.....	p.3
SECTION 3. PURPOSE.....	p.3
SECTION 4. JURISDICTION.....	p.3
SECTION 5. INTERPRETATION.....	p.3
SECTION 6. ADOPTION OF TECHNICAL CODES.....	p.3
SECTION 7. AMENDMENTS TO ADOPTED CODES.....	p.4
INTERNATIONAL BUILDING CODE AMENDMENTS.....	p.4
INTERNATIONAL RESIDENTIAL CODE AMENDMENTS.....	p.9
INTERNATIONAL PLUMBING CODE AMENDMENTS.....	p.18
INTERNATIONAL MECHANICAL CODE AMENDMENTS.....	p.20
INTERNATIONAL FUEL GAS CODE AMENDMENTS.....	p.22
INTERNATIONAL ENERGY CONSERVATION CODE.....	p.24
INTERNATIONAL EXISTING BUILDING CODE AMENDMENTS.....	p.26
TABLE 1. WHEN PERMITS ARE REQUIRED.....	p.27
SECTION 8. REPEAL.....	p.29
SECTION 9. SEVERABILITY.....	p.29

**SECTION 1. TITLE.** This resolution shall be known as the County Building Codes Resolution of Teton County, Wyoming.

**SECTION 2. AUTHORITY.** The County Building Codes Resolution of Teton County is authorized by W.S. Sections 35-9-101 through 35-9-121 and 18-5-201 through 18-5-207.

**SECTION 3. PURPOSE.** This chapter is enacted to provide for the minimum requirements to safeguard life or limb, health, and the public safety and welfare and the protection of property by regulating and controlling the construction, alteration, removal, demolition, equipment, materials, use and occupancy of all buildings and structures, providing for the issuance of permits and collection of fees therefore within the unincorporated portions of Teton County and for the placing and maintenance therein of the electrical wiring and appliances, plumbing and gas installations.

**SECTION 4. JURISDICTION.** The territorial jurisdiction of this chapter shall include all of the unincorporated lands within Teton County.

**SECTION 5. INTERPRETATION.** In their interpretation and application, the provisions of this Resolution shall be held to be minimum requirements. No provision of this Resolution is intended to repeal, abrogate, annul, impair or interfere with any existing Resolution of the County, except as is specifically repealed by adoption of this Resolution, provided that where any provision of this Resolution imposes more stringent regulations, requirements or limitations than are imposed by any other Resolution of Teton County, or any statute of the State of Wyoming, or regulation of any of its departments, then the provisions of this Resolution shall govern.

All of the nationally recognized model codes upon which this Resolution is based are comprehensive and flexible and make provision for the use of all safe materials or methods of construction. Consequently, there are construction materials and practices other than referred to in this code that may be adequate for the purposes intended. These other methods represent either seldom used or new systems or performance type systems that require individual consideration by the professional architect or engineer and approval by the Teton County Building Official based on test data, engineering analysis and listings and are therefore not included herein.

**SECTION 6. ADOPTION OF TECHNICAL CODES.** In order to carry out the purposes set forth above, each of the following technical codes, (except for portions thereof specifically excluded by the County Commissioners from time to time) are hereby adopted by reference:

- A. The International Building Code, 2024 edition, including Appendix C, Group U-Agricultural Buildings; Appendix I, Patio Covers, as published by the International Code Council.
- B. The International Residential Code, 2024 edition, including Appendix BB Tiny Houses and Appendix BE, Radon Control Methods

- C. International Plumbing Code, 2024 edition, including Appendix E, Sizing of Water Piping System, as published by the International Code Council.
- D. International Mechanical Code, 2024 edition, including Appendix A, Combustion Air Openings and Chimney Connector Pass-Throughs, as published by the International Code Council.
- E. International Fuel Gas Code, 2024 edition, specifically excluding all appendices.
- F. International Energy Conservation Code, 2021 edition, specifically excluding all appendices.
- G. International Existing Building Code, 2024 edition, including Appendix A, Guidelines for the Seismic Retrofit of Existing Buildings.
- H. International Property Maintenance Code 2024 edition as such code is referenced in the International Building Code, the International Fire Code, the International Mechanical Code, and the International Fuel Gas Code, but only to the extent that the referenced provisions apply to fire and life safety.

## SECTION 7 AMENDMENTS TO ADOPTED CODES.

### INTERNATIONAL BUILDING CODE AMENDMENTS

- A. THE INTERNATIONAL BUILDING CODE 2024 IS SPECIFICALLY AMENDED AS FOLLOWS:

**101.4.3 Plumbing:** The last sentence shall be amended to read: The provisions of Title 9 Small Waste Water Facility Regulations adopted by the Teton County Engineering Division.

**Section 101.4.4 Property maintenance.** Amend by adding: to the last sentence; as such code is referenced in the International Building Code, the International Fire Code, the International Mechanical Code, and the International Fuel Gas Code, but only to the extent that the referenced provisions apply to fire and life safety.

**Section 101.4.8 Electrical.** Amend by adding section 101.4.8 Electrical. The provisions of the 2023 National Electrical Code shall apply to the installation of electrical systems, including alterations, repairs, replacement, equipment, appliances, fixtures, fittings and appurtenances thereto.

**Section 103.1 Creation of enforcement agency.** Change “Department of Building Safety” to “Teton County Building Department.”

**Section 103.3. Deputies.** Delete the last sentence.

**Section 104.2.3.8** Amend by Adding. 104.2.3.8 Structural Insulated Panel (SIPs) Roof Assemblies. All roofs utilizing Structural Insulated Panels shall include a cold roof ventilation design approved by the Building Official

**Section 105.2 Work Exempt from Permit:**

Item 11 is amended to read as follows: Swings and other playground equipment.

Add item 14: Private use agricultural buildings, limited to one structure per parcel, with a roof eave height not to exceed 10 feet. and a roof area not exceeding 600 square feet, defined as a structure designed and constructed to house farm implements, hay, grain, poultry, livestock or other horticultural products placed on a lot or parcel over 2 acres in size. This structure shall not be a place of human habitation or a place of employment where agricultural products are processed, treated or packaged, nor shall it be a place used by the public. This section does not exempt any person from the requirements of obtaining other permits required by law, including but not limited to plumbing, mechanical, electrical, or septic permits or permits required under the Teton County Land Development Regulations.

**Section 105.3.2 Time limitation of application.** Amended to read: An application for a permit for any proposed work shall be deemed to have been abandoned 180 days after the date of filing, unless such application has been pursued in good faith or a permit has been issued.

**Section 105.5 Expiration.** Amend second sentence to read: The Building Official is authorized to grant, in writing, a maximum of two (2) extensions of time, for periods not more than 180 days each.

**Section 109.2 Schedule of permit fees.** Amend to read as follows: The fee for building permits shall be as follows: Building Permit Fees will be established using the most current Building Valuation Data published by The International Code Council and a Permit Fee Multiplier as established in the Schedule of Fees from the Teton County Planning & Building Services Department. The multiplier and valuation for remodels and the minimum fees for building and miscellaneous permits shall also be as established in the Schedule of Fees.

On structures requiring gas, mechanical, or plumbing systems, a separate fee for each permit shall be assessed as required, in accordance with the Schedule of Fees from the Teton County Planning & Building Services Department. Electrical permit fees shall be determined by the Electrical Division of the Jackson Hole Fire/EMS Department.

The fees for all energy work shall be as indicated in the Schedule of Fees from the Teton County Planning & Building Services Department. The fee schedule shall be in effect as of the effective date of this resolution.

Permit Fee Multipliers may be adjusted as deemed necessary under the direction of the Teton County Commissioners.

**Section 109.2.1 Plan review fees.** Add Section 109.2.1 Schedule of plan review fees. When submittal documents are required by Section 107.1, a Plan Review Fee shall be paid at the time of submitting the submittal documents for plan review. Said Plan Review Fee shall be 65 percent of the Building Permit Fee.

The Plan Review Fees specified in this section are separate fees from the Permit Fees specified in section 109.2 and are in addition to the Permit Fees.

When submittal documents are incomplete or changed so as to require additional plan review or when the project involves deferred submittal items as defined in Section 107.3.4.1, an additional Plan Review Fee shall be charged at the rate shown in the Schedule of Fees from the Teton County Planning & Building Services Department

**Section 109.3 Building Permit Valuations.** Amended as follows: The valuation for Building Permits in Teton County shall be based on the most recent cost figures per square foot as shown in International Building Code, Building Valuation Data Table published by International Code Council. The latest Building Valuation Table may be found at [www.iccsafe.org](http://www.iccsafe.org) or at the Teton County Building Department Office.

**Section 109.4 Work commencing before permit issuance.** Add last sentence: The fee shall be double the permit fee.

**Section 109.6 Refunds.** Amend to read as follows:

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of plan review fee payment, and then only under the following conditions:

1. The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.
2. The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.
3. The Building Official may authorize refunding of not more than 80 percent of the fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or cancelled before any plan review effort has been expended.

**Section 110.3.10.1 Reinspection and testing.** Add Section 110.3.10.1 Reinspection and Testing as follows: When required a reinspection fee may be assessed for the following circumstances: For each reinspection that results from the applicant either not completing all or a portion of the work for which an inspection was previously requested; for not providing the approved plans to the inspector at the time of any inspection; for failure to provide access on the date and time for which the inspection is requested; for deviating from the plans without prior approval of the Building Official.

If assessed the fees shall be charged at the rate shown in the Schedule of Fees from the Teton County Planning & Building Services Department. Additional work and/or inspections may be prohibited until reinspection fees have been paid and/or needed corrections have been completed.

**Section 117, License required.** Add Section 117 License required as follows:

Contractors performing work requiring a permit under this code shall be required to be licensed and have in their possession a contractor's license issued by the Town of Jackson, Wyoming.

Exceptions:

1. Owner(s) of a single family home performing work on their primary residence or associated outbuildings for their personal use. For purposes of this exception, homeowners who construct more than one house every two years, before receiving a Certificate of Occupancy or Completion, in Teton County shall be considered contractors and shall be licensed.
2. Work being performed that does not require licensing by the Town of Jackson.

**Section 305.2 Group E, Day Care Facilities** shall be revised to read, "The use of a building or structure, or portion thereof, for educational, supervision or personal care services for ten or fewer children older than 2-1/2 years of age, shall be classified as a Group E occupancy."

**Section 308.5.4 Five or fewer persons receiving care in a dwelling unit.** shall be revised to read: "A facility such as the above with ten or fewer persons shall be classified as a Group R-3 or shall comply with the International Residential code in accordance with Section 101.2."

**Section 901.7 Fire Areas. Revise to read as follows:** Where structures or portions thereof, are 5,000 square feet or larger, the building shall be protected by an approved automatic fire sprinkler system, installed in accordance with further requirements of the IBC, IFC, and/or NFPA 13, 13D or 13R, whichever applies based on type of occupancy.

For the purpose of determining fire area for the amended portion of section 903.2 (buildings 5,000 square feet and larger) square footage calculations shall be measured from the exterior surface of framing members encompassing the perimeter of the Fire Area, from the interior surface of concrete or masonry walls that are 50% or more below grade, and for log construction to the exterior surface of foundations or supporting elements.

**Section 903.2 Where required.** Add the following: All structures, regardless of occupancy, 5,000 square feet or larger, shall be protected by an approved automatic fire sprinkler system, installed in accordance with further requirements of the IBC and/or NFPA 13, 13D or 13R, whichever applies based on type of occupancy.

**EXCEPTIONS:** Agricultural buildings. Where uses other than residential occur within an agricultural building, and comprise not more than 10% of the floor area of such building, an automatic fire extinguishing system may be omitted unless otherwise required by other provisions as adopted by Teton County.

**Section 903.2.1.1 Group A-1.** Revise to read as follows: 1. The building is 5,000 square feet or larger.

**Section 903.2.1.2 Group A-2.** Revise to read as follows: 1. The building is 5,000 square feet or larger.

**Section 903.2.1.3 Group A-3.** Revise to read as follows: 1. The building is 5,000 square feet or larger.

**Section 903.2.1.4 Group A-4.** Revise to read as follows: 1. The building is 5,000 square feet or larger.

**Section 903.2.3 Group E.** Revise to read as follows: 1. Throughout all Group E buildings greater than 5,000 square feet or larger.

**Section 903.2.4 Group F-1.** Revise to read as follows: 1. Where the building is 5,000 square feet or larger.

**Section 903.2.7 Group M.** Revise to read as follows: 1. Where the building is 5,000 square feet or larger.

**Section 903.2.9 Group S-1.** Revise to read as follows: 1. Where the building is 5,000 square feet or larger.

**Section 903.2.9.1 Repair garages.** Amend to read as follows:

1. Buildings two or more stories in height, including basements, that are 5,000 square feet or larger.
2. One-story buildings that are 5,000 square feet or larger.

**Section 907.2.1 Group A.** Change the exception 1 to read, Exception: Manual fire alarm boxes may be omitted when approved by the Fire Code Official and where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate throughout the notification zones upon sprinkler water flow.

**Section 907.2.2 Group B.** Change the exception to read, Exception: Manual fire alarm boxes may be omitted when approved by the Fire Code Official and where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate throughout the notification zones upon sprinkler water flow.

**Section 907.2.4 Group F.** Change the exception to read, Exception: Manual fire alarm boxes may be omitted when approved by the Fire Code Official and where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate throughout the notification zones upon sprinkler water flow.

**Section 907.2.7.1 Group M.** Change the exception 2 to read, Exception: Manual fire alarm boxes may be omitted when approved by the Fire Code Official and where the building is equipped throughout with an automatic sprinkler system installed in accordance with Section 903.3.1.1 and the occupant notification appliances will activate throughout the notification zones upon sprinkler water flow.

**Section 1031.2 Where required.** Delete Exception 5 in its entirety

**Section 1505.1 General.** Amend by adding the following as the last sentence: All new roofing and re-roofing shall be provided with a minimum of class B roof covering.

**Section 1608.2 Ground snow load.** Add sentence at the end to read: Ground snow loads shall be those shown on the ASCE Hazard Tool <https://ascehazardtool.org/> for the risk category on Table 1604.5.

**Section 1805.1.2 Under Floor Space.** The second sentence shall be revised to read “Where there is evidence that the seasonal ground water table rises to the elevation of the bottom floor of the crawl space, the ground level of the under floor space shall elevated to a minimum of 12 inches above such elevation unless an approved drainage system is provided”.

**Section 1809.5 Frost Protection.** Amended and replace to read: Foundation walls, piers and other permanent supports of buildings and structures shall be protected from frost by the following method; Footings subject to frost shall have a minimum depth of 34-inches measured from finish grade to the bottom of the footing or the depth otherwise specified by the Soils Engineer of record.

**Section 1809.12 Timber Footings.** Amend as follows: Delete entire section.

## INTERNATIONAL RESIDENTIAL CODE AMENDMENTS

B. THE INTERNATIONAL RESIDENTIAL CODE 2024 IS SPECIFICALLY AMENDED AS FOLLOWS:

**R101.1 Title.** Revise to read as follows: These provisions shall be known as the *Residential Code for One- and Two-Family Dwellings* of Teton County, and shall be cited as such and will be referred to herein as “this code.”

**R102.6 Existing Structures.** Revise to read as follows: The legal occupancy of any structure existing on the date of adoption of this code shall be permitted to continue without change, except as is specifically covered in this code or the *International Fire Code*, or as is deemed necessary by the Building Official for the general safety and welfare of the occupants and the public.

**R103.1 Creation of agency.** Insert Teton County Building Department

**Section R104.2.2 Alternative materials, design and methods of construction and equipment.** Amend by Adding. R104.2.2.7 Structural Insulated Panel (SIPs) Roof Assemblies. All roofs utilizing Structural Insulated Panels shall include a cold roof ventilation design approved by the Building Official.

**R105.2 Work exempt from a permit.** Amend to read as follows: 1. One-story detached accessory structures, limited to one such structure per lot or parcel, and provided the floor area does not exceed 200 square feet.

**Add the following 11.** Private use agricultural buildings, limited to one structure per parcel, with a roof eve height not to exceed 10 feet, and roof area not exceeding 600 square feet, placed on a lot or parcel over 2 acres in size, designed and constructed to house farm implements, hay, grain, poultry, livestock or other horticultural products. This structure shall not be a place of human habitation or a place of employment where agricultural products are processed, treated or packaged, nor shall it be a place used by the public. This section does not exempt any person from the requirements of obtaining other permits required by law, including but not limited to plumbing, mechanical, electrical, and septic permits or permits required under the Teton County Land Development Regulations.

**Add Item 12. Hoop houses.** Floor area not to exceed 3500 square feet per structure, and a maximum height of 16 feet. Hoop houses shall not have any potable or sanitary plumbing, electrical or mechanical utilities connected to the structure. A hoop house shall have framing members of schedule 40 (Minimum) PVC or metal piping with a covering of a 6 mil minimum industrial or industry approved material. Exempt structures shall comply with the setback requirements of the Land Development Regulations (LDRs). Structures not considered to be hoop houses shall be required to obtain a building permit.

**R108.2 Schedule of permit fees.** Amend to read as follows: The fee for building permits shall be as follows: Building Permit Fees will be established using the most current Building Valuation Data published by The International Code Council and a Permit Fee Multiplier as established in the Schedule of Fees from the Teton County Planning & Building Services Department. Schedule of Fees from the Teton County Planning & Building Services Department. The multiplier and valuation for remodels and the minimum fees for building and miscellaneous permits shall also be as established in the Schedule of Fees.

On structures requiring gas, mechanical, or plumbing systems, a separate fee for each permit shall be assessed as required, in accordance with the Schedule of Fees from the Teton County Planning & Building Services Department. Electrical permit fees shall be determined by the Electrical Division of the Jackson Hole Fire/EMS Department.

Permit Fee Multipliers may be adjusted as deemed necessary under the direction of the Teton County Commissioners.

**R108.2.1 Plan review fees.** Add Section R108.2.1 Schedule of permit fees. When submittal documents are required by Section 106.1, a Plan Review Fee shall be paid at the time of submitting the submittal documents for plan review. Said Plan Review Fee shall be 65 percent of the Building Permit Fee as shown in the Schedule of Fees from the Teton County Planning & Building Services Department.

The Plan Review Fees specified in this section are separate fees from the Permit Fees specified in section 108.2 and are in addition to the Permit Fees.

When submittal documents are incomplete or changed so as to require additional plan review or when the project involves deferred submittal items as defined in Section 106.1, an additional plan review fee shall be charged at the rate shown in the Schedule of Fees from the Teton County Planning & Building Services Department.

**R108.3 Building permit valuations.** Section R108. Building permit valuations is amended as follows: The valuation for Building Permits in Teton County shall be based on the most recent cost figures per square foot as shown in the International Building Code, Building Valuation Data, published by the International Code Council. The latest Building Valuation Data Table may be found at [www.iccsafe.org](http://www.iccsafe.org) or at the Teton County Building Department Office.

**R108.4.1 Work commencing before permit issuance.** Add Section R108.4.1. Work commencing before permit issuance. An investigation fee, in addition to the permit fee, may be collected in cases where the owner, contractor, or applicant, as the case may be, begins work prior to the issuance of the necessary permits, whether or not a permit is then or subsequently issued. The minimum investigation fee shall be equal to the amount of the permit fee required by this code as set forth in Section R108.2 of the Schedule of Fees from the Teton County Planning & Building Services Department. The payment of such investigation fee shall not exempt any person from compliance with all other provisions of this code nor from any penalty prescribed by law.

**R108.5 Refunds.** Amend to read as follows:

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of plan review fee payment, and then only under the following conditions:

1. The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.
2. The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.
3. The Building Official may authorize refunding of not more than 80 percent of the fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or cancelled before any plan review effort has been expended.

**Section R109.1.5.2 Reinspection and testing.** Add Section R109.1.5.2 Reinspection and Testing as follows:

A reinspection fee may be assessed for the following circumstances: For each reinspection that results from the applicant either not completing all or a portion of the work for which an inspection was previously requested; for not providing the approved plans to the inspector at the time of any inspection; for failure to provide access on the date and time for which the inspection is requested; for deviating from the plans without prior approval of the Building Official.

If assessed the applicant shall pay the reinspection fee as set forth in the Schedule of Fees from the Teton County Planning & Building Services Department. Depending on the circumstance additional work and/or inspections may be prohibited until reinspection fees have been paid and/or needed corrections have been completed.

**Section R115, License required.** Add Section R115 License required as follows:

Contractors performing work requiring a permit under this code shall be licensed and have in their possession a contractor's license issued by the Town of Jackson, Wyoming.

Exceptions:

3. Owner(s) of a single family home performing work on their primary residence or associated outbuildings for their personal use. For purposes of this exception, homeowners who construct more than one house every two years in Teton County shall be considered contractors and shall be licensed.
4. Work being performed that does not require licensing by the Town of Jackson.

**SECTION R202 Definitions.** Amend this section by adding the following definitions:

**Approved Solid Fuel Heating Device (ASFHD).** ASFHD are those devices whose primary use is heating which include but are not limited to pellet stoves and inserts, corn stoves and inserts or any other device with emissions of 1 gram or less of particulate per hour, capable of being vented within 4 feet. of an operable window and approved by the Building Official.

**Bedroom.** An area or room meeting all of the requirements of Sections R304, R305, R310, and R311 that is directly connected to a dwelling unit and has access through the conditioned area of the dwelling unit to facilities for eating cooking and bathing.

**Green house** means a structure with the sides primarily made of a transparent material such as glass or Perspex for the purpose of rearing delicate plants or hastening growth of plants under controlled environmental conditions.

**Hoop house** means a single story unoccupied structure with structural members that are made of flexible and somewhat rigid construction materials, typically PVC pipe or similar material. The ends may be covered or left open and the material covering the structural members is readily removable and is typically removed and re-affixed frequently. Hoop houses shall not have a workstation or repair shop and shall be used exclusively for the growing and storage of food, herbs, or ornamental crops.

**Kitchen.** Kitchen shall mean an area used, or designated to be used, for the preparation of food and shall contain permanent provisions for the cooking, storage, and preparation of food consisting of a sink, refrigerator, oven and/or a cook top.

**Solid Fuel Heating Device (SFHD).** SFHD are those devices whose primary use is heating which include but are not limited to certain brands of wood stoves and inserts, and masonry heaters or any other device capable of controlling combustion through mechanical means and approved by the Building Official. *This definition shall specifically exclude fireplaces or barbeques.*

**Solid Fuel Decorative Device (SFDD).** SFDD are devices whose primary use is esthetic or decorative and shall include masonry and manufactured fireplaces or any other solid fuel, free burning device constantly open to view and approved by the Building Official.

**R301.1.1.2 Design.** Add section R301.1.1.2

.: All Single Family Dwellings and Accessory structures, 5,000 square feet or larger, shall be protected by an approved automatic fire sprinkler system, installed in accordance with further requirements of the IRC, IFC and/or NFPA 13, 13D or 13R, whichever applies based on type of occupancy.

**EXCEPTIONS:**

1. Agricultural buildings. Where uses other than residential occur within an agricultural building, and comprise not more than 10% of the floor area of such building, an automatic fire extinguishing system may be omitted unless otherwise required by other provisions as adopted by Teton County.
2. Additions to existing residences built after October 1<sup>st</sup> 1991, may use the 2 hour fire barrier provision to separate the fire areas to 5000 sq. ft. or less on each side of the fire barrier, shall not be required to provide sprinkler protection provided that all provisions are met:
  - a. The door or doors separating the areas shall be 90 minute rated, self-closing and provided with hold-open devices actuated to release on detection of smoke by detectors located on each side of the door or by the loss of power.
  - b. Ducts that penetrate fire barrier shall have fire damper that is fire-resistance-rated to 90 minutes.
3. Buildings permitted on or before October 1<sup>st</sup> 1991.

**EXCEPTION:** Buildings permitted on or before October 1<sup>st</sup> 1991 with additions permitted for construction after that date, totaling 5000 square feet or larger, shall be required to be protected by an approved sprinkler system throughout or may have the additions only, protected by an approved sprinkler system, provided they are separated from the existing construction by a two hour fire barrier approved by the Building Official and Jackson Hole Fire/EMS.

For the purpose of this section, square footage calculations shall be measured from the exterior surface of framing members encompassing the perimeter of the Fire Area, from the interior surface of exterior concrete or masonry walls that are 50 % or more below grade, and for log construction to the exterior surface of foundations or supporting elements.

**R301.1.3. Engineered Design.** Revise the last sentence to read: Except for detached non-habitable structures less than 600 square feet, buildings shall be designed by a civil or structural engineer licensed in the State of Wyoming.

**Table R 301.2 Climactic and Geographical Design Criteria**

<b>Ground Snow Load</b>	See Foot Note k
<b>Wind Speed</b>	105MPH foot note d
<b>Topographical Effects</b>	NO
<b>Special Wind Region</b>	NO
<b>Windborne Debris Zone</b>	NO
<b>Seismic Design Category</b>	D1,D2 foot note f
<b>Weathering</b>	Severe foot note a
<b>Frost Line Depth</b>	34inches foot note b

<b>Termite</b>	Slight foot note c
<b>Ice Barrier Underlayment Required</b>	YES
<b>Flood Hazard</b>	See Foot Note g
<b>Air Freezing Index</b>	3500
<b>Mean Annual Temp</b>	38 degrees foot note j

For SI: 1 pound per square foot=0.0479 kN/m<sup>2</sup>, 1 mile per hour=1.609km/h.

- a. Probability Map [Figure R301.2 (3)]. Concrete shall conform to the “severe” requirements of Table R402.2. The grade of masonry units shall be determined from ASTM C34, C55, C62, C73, C90, C129, C145, C216 or C652.
- b. The frost line depth for Teton County is 34-inches measured from finished grade to the bottom of footings or as determined by a soils investigation.
- c. Teton County shall be considered “none to slight” in accordance with figure R301.2(6).
- d. The basic wind speed shall be 105 as determined from the wind speed map [Figure R301.2(2)]. Wind exposure category shall be determined on a site-specific basis in accordance with Section R301.2.1.4.
- e. The outdoor design dry-bulb temperature shall be -30 Fahrenheit.
- f. The minimum Seismic Design Category for Teton County as determined from Section R301.2.2.1 is D.
- g. The date of Teton County’s entry into the National Flood Insurance Program is May 4<sup>th</sup> 1989; September 16<sup>th</sup> 2015 is the currently effective FIRM and FBFM, or other flood hazard map adopted by the community, as may be amended.
- h. The Mean Annual Temperature is 38.0 Fahrenheit and the Air Freezing Index Return Periods & Associated Probabilities 100 Year (99%) is 2531. Prepared by NOAA – National Climatic Data Center.
- i. The Mean Annual Temperature is 38.0 Fahrenheit and the Air Freezing Index Return Periods & Associated Probabilities 100 Year (99%) is 2531. [www.ncdc.noaa.gov/fpsf.html](http://www.ncdc.noaa.gov/fpsf.html).
- j. Source - [www.ncdc.noaa.gov/fpsf.html](http://www.ncdc.noaa.gov/fpsf.html).
- k. As shown on the ASCE Hazard Tool <https://ascehazardtool.org/> for the risk category in Table 1604.5 of the 2024 IBC

**TABLE R302.6 Separation required.** Amend by changing all references of  $\frac{1}{2}$  inch gypsum board to read as follows: 5/8-inch type X gypsum board.

**R302.7 Under-stair protection:** Revised to read: Enclosed accessible space under stairs shall have walls, under stair surface and any soffits protected on the enclosed side with 5/8 inch gypsum board.

**R309 Delete in its entirety**

**R302.12 Draftstopping.** Amend by adding section R302.12.1.2. Cold Roof Assemblies, Cold Roof Assemblies shall have draft stops installed so that the area of the concealed space does not exceed 1000 square feet.

**R302.13 Protection of Floors.** Delete entire Section.

**R312.3 Height effect on room area.** Amend to read as follows: Portions of a room with a sloping ceiling measuring less than 5 feet (1524 mm) or a furred ceiling measuring less than 7 feet (2134 mm) from the finished floor to the finished ceiling shall not be considered as contributing to the minimum required habitable area for that room. Rooms or areas that are not approved as habitable space, or do not meet the definition, or minimum dimensions for size and height of habitable space shall not contain electrical outlets, light switches, plumbing fixtures, or terminations for phone, internet, or cable wiring, unless specifically required by another section of the adopted resolutions of Teton County.

**Exception:** Approved garages and accessory structures (such as workshops, studios, or studies and similar structures incidental to the primary dwelling unit), providing they meet the minimum dimensional requirements of habitable space for size, height and area.

**R318.7.11.1 Spiral stairways.** Amend by adding the following: The maximum diameter of the inside radius of the stairs shall not exceed 12 inches. Spiral stairs shall not serve as a primary means of egress for any dwelling unit. Spiral stairs shall not serve as the primary means of egress from any story or area within a dwelling having a gross square footage greater than 500 square feet.

**R319.1 Emergency Escape and Rescue Openings.** Delete Exception 3 in its entirety.

**R326.2 Kitchen.** Amend to read as follows: Every dwelling unit shall be provided with a kitchen area and every kitchen area shall be provided with a sink, refrigerator, oven and/or a cook top.

**R403.3 Frost protected shallow foundations.** Amend to read: Frost protected shallow foundations are prohibited.

**R904.1 Scope.** Add the following sentence: All new roofing and re-roofing shall have a minimum class B rating.

**R1001.1General:** Amend by adding the following: Installation of Solid Fuel Heating Devices (SFHD) and Solid Fuel Decorative Devices (SFDD) is prohibited.

Exceptions:

1. A maximum of one SFHD may be installed in any detached single family dwelling.
2. A maximum of one SFDD may be installed in any detached single family dwelling. Properties a minimum of three acres in size may be permitted one additional SFDD and one additional SFDD for each additional acre in excess of three acres, up to a maximum of four SFDDs.
3. SFDDs shall be allowed for commercial developments when proposed to and approved by the Teton County, Board of County Commissioners as part of the Development Permit process.
4. Approved Solid Fuel Heating Devices (ASFHD) are exempt from the provisions of this section.

## **Chapter 11 Energy Efficiency**

Refer to Section F of this Resolution for the International Energy Conservation Code

**M1414.1 General.** Amend by adding the following: Installation or re-location of a Solid Fuel Heating Device is prohibited unless the device meets the minimum requirements for Phase II emissions as established by the EPA at the time of its installation.

**M1501.1 Outdoor discharge.** Add the following: Required back draft dampers shall be installed at the duct termination. Ducts shall be installed on the warm side of insulation from inside the building envelope to the exterior veneer of the building.

**M1503.2.1 Open-top broiler exhaust.** Delete exception.

**M1503.3 Exhaust discharge.** Exception can only be used for remodels and only if the kitchen fan installation would require existing finishes to be removed.

**M1504.1 Duct construction.** Amend by adding the following sentence: All exhaust ducts shall be constructed of rigid metal having smooth interior surfaces with male joints running in the direction of air flow.

Add section **M1701.1.1 Buildings of unusually tight construction.** Shall read: In all structures containing habitable space or unusually tight construction, combustion air shall be obtained from outside the thermal envelope.

**M1801.1 Venting required.** Amend first sentence to read: Fuel-burning appliances shall be vented to the outdoors in accordance with their listing and label and manufacturer's installation instructions.

**G2406.2 (303.3) Prohibited locations.** Delete the following conditions to the exception; 3, 4.

**G2407.1 (304.1) General.** Amend by adding the following as the first sentence: In all structures containing habitable space or unusually tight construction, combustion air shall be obtained from outside the building thermal envelope.

**G2414.4.3 (403.4.3) Copper tubing.** Revise to read as follows: Copper or brass tubing shall not be used for installations of gas piping systems.

**G2420.3 (409.3.2) Individual buildings.** Revise to read as follows: Shut off valves shall be installed outdoors at all buildings where the supply enters the building.

**G2432.1 (602.1) Decorative Appliances for Installation in Fireplaces.** Amend by adding the following sentence: Decorative appliances installed in residential occupancies shall be listed and labeled to allow for installation of glass doors and shall be listed and labeled to operate with the doors in the closed position.

**Exception:** An approved Flue Sentinel may be installed with an electrical interlock in conjunction with the decorative appliance only if the doors are not installed on the fireplace.

**G2433.1 (603.1) LOG LIGHTERS. General.** Amend by adding the following sentence: All gas fired log lighters shall be provided with a listed pilot safety device installed in accordance with the manufacturer's installation requirements.

**G2445.4 (621.4) Prohibited locations.** Amend to read as follows: Unvented room heaters shall not be installed in dwelling units, normally occupied spaces, or any area meeting the definition of unusually tight construction and shall also comply with the requirements of Section G2406.2.

**G2445.7 Unvented decorative room heaters.** Add a second sentence to read: Unvented log heaters shall not be installed in habitable rooms or spaces or any space meeting the requirements of unusually tight construction.

**P2603.5 Freezing.** Revise the last sentence to read: Water service pipe shall be installed not less than 72 inches deep.

**P2603.5.1 Sewer depth.** Revise to read as follows: P2603.5.1 Sewer depth. Building sewers that connect to private sewage disposal systems shall be a minimum of 24 inches below finished grade at the point of septic tank connection. Building sewers shall be a minimum of 48 inches below grade. All building sewers that do not meet the minimum required depth below grade shall be protected from freezing by insulation, heating or both.

**P3103.1.1 Roof extension.** Amend to read: Open vent pipes that extend through a roof shall be terminated 16 inches above the roof or 6 inches above the anticipated snow accumulation level, whichever is greater.

Delete Chapter E34 thru E40 in their entirety

## INTERNATIONAL PLUMBING CODE AMENDMENTS

C. THE INTERNATIONAL PLUMBING CODE 2024 IS SPECIFICALLY AMENDED AS FOLLOWS:

**101.1 Title.** Amend to read as follows: These regulations shall be known as the International Plumbing Code of Teton County, and shall be cited as such and will be referred to herein as “this code”.

**101.1.1.** All references to “code official” in this code to shall mean Teton County Building Official.

**103.1 Creation of agency.** Insert Teton County Building Division

**108.2 Fee Schedule.** Amend to read as follows: The fees for all plumbing work shall be as indicated in the Schedule of Fees from the Teton County Planning & Building Services Department

**108.4 Work commencing before permit issuance.** Add last sentence, The permit fee shall be double.

**108.6 Refunds.** Amend to read as follows:

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of plan review fee payment, and then only under the following conditions:

1. The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.
2. The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.
3. The Building Official may authorize refunding of not more than 80 percent of the fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or cancelled before any plan review effort has been expended.

If assessed the applicant shall pay the reinspection fee as set forth in the fee schedule adopted by Teton County. Depending on the circumstance, additional work and/or inspections may be prohibited until reinspection fees have been paid and/or needed corrections have been completed.

**Section 111.4.3.1 Reinspection and testing.** Add Section 111.4.3.1 Reinspection and Testing as follows: A reinspection fee may be assessed for the following circumstances:

For each reinspection that results from the applicant either not completing all or a portion of the work for which an inspection was previously requested; for not providing the approved plans to the inspector at the time of any inspection; for failure to provide access on the date and time for which the inspection is requested; for deviating from the plans without prior approval of the building official.

**114.4 Violation penalties.** Amend to read: Any person who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter or repair plumbing work in violation of the approved construction documents or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be subject to penalties as prescribed by law.

**Section 116, License required.** Add Section 116 License required as follows:

Contractors performing work requiring a permit under this code shall be licensed and have in their possession a contractor's license issued by the Town of Jackson, Wyoming.

Exceptions:

1. Owner(s) of a single family home performing work on their primary residence or associated outbuildings for their personal use. For purposes of this exception, homeowners who construct more than one house every two years in Teton County shall be considered contractors and shall be licensed.
2. Work being performed that does not require licensing by the Town of Jackson.

**305.4. Freezing.** Amend the last sentence to read: Exterior water supply system piping shall be installed not less than 6 feet below finished grade.

**305.4.1 Sewer depth.** Amend to read: Building sewers that connect to private disposal systems shall be a minimum of 24 inches below finished grade at the point of septic tank connection. Building sewers shall be a minimum of 48 inches below finished grade.

**416.3 Commercial food waste disposer waste outlets.** Amend the second sentence to read: Commercial food waste disposers shall not be installed in commercial kitchens unless connected to an approved grease interceptor with a minimum liquid capacity of 750 gallons.

**608.17.4 Connections to automatic fire sprinkler systems and standpipe systems.** Amend to read as follows: The potable water supply to automatic fire sprinkler and standpipe systems shall be protected against backflow by a reduced pressure principle backflow prevention device.

**903.1.1 Roof extensions.** Amend to read: All open vent pipes that extend through a roof shall be terminated at least 16 inches above the roof.

**903.1.2 Roof used for recreational or assembly purposes.** Amend to read: Where a roof is to be used for any purpose other than weather protection, the vent extensions shall be run at least 7 feet above the roof.

**903.2 Frost closure.** Amend the first sentence to read: Every vent extension through a roof or wall shall be a minimum of 3 inches in diameter.

**1003.3.2 Food Waste disposers.** Amend to read: Food waste disposers shall not be connected to a grease interceptor with a liquid capacity of less than 750 gallons.

**1106.1 General.** Amended to read as follows: The size of the vertical conductors and leaders, of building storm drains, building storm sewers, and any horizontal branches of such drains or sewers shall be based on the 100-year hourly rainfall rate of 1.8 inches.

# INTERNATIONAL MECHANICAL CODE AMENDMENTS

D. THE INTERNATIONAL MECHANICAL CODE 2024 IS SPECIFICALLY AMENDED AS FOLLOWS:

**101.1 Title.** Revise to read as follows: These regulations shall be known as the *Mechanical Code* of Teton County, hereinafter referred to as “this code.”

**101.1.1.** All references to “code official” in this code to shall mean Teton County, Building Official.

**103.1 Creation of agency.** Insert Teton County Building Department.

**108.2 Fee schedule.** Revise to read as follows: The fees for mechanical work shall be as indicated in the Schedule of Fees from the Teton County Planning & Building Services Department

**108.4 Work Commencing before permit issuance.** Add sentence at the end: The permit fee shall be double.

**108.6 Refunds.** Amend to read as follows:

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of plan review fee payment, and then only under the following conditions:

1. The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.
2. The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.
3. The Building Official may authorize refunding of not more than 80 percent of the fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or cancelled before any plan review effort has been expended.

**111.3.3 Reinspection and testing.** Add Section 111.3.3 Reinspection and Testing as follows:

A reinspection fee may be assessed for the following circumstances:

For each reinspection that results from the applicant either not completing all or a portion of the work for which an inspection was previously requested; for not providing the approved plans to the inspector at the time of any inspection; for failure to provide access on the date and time for which the inspection is requested; for deviating from the plans without prior approval of the building official.

If assessed the applicant shall pay the reinspection fee as set forth in the Schedule of Fees from the Teton County Planning & Building Services Department. Depending on the circumstance additional

work and/or inspections may be prohibited until reinspection fees have been paid and/or needed corrections have been completed.

**114.4 Violation penalties.** Amend to read: Any person who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter or repair mechanical work in violation of the approved construction documents or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be subject to penalties as prescribed by law.

**116 License required.** Add Section 116 License required as follows:

Contractors performing work requiring a permit under this code shall be licensed and have in their possession a contractor's license issued by the Town of Jackson, Wyoming.

Exceptions:

1. Owner(s) of a single family home performing work on their primary residence or associated outbuildings for their personal use. For purposes of this exception, homeowners who construct more than one house every two years in Teton County shall be considered contractors and shall be licensed.
2. Work being performed that does not require licensing by the Town of Jackson.

**SECTION 202 GENERAL DEFINITIONS.** Amend this section by adding the following definitions.

**Approved Solid Fuel Heating Device (ASFHD).** ASFHD are those devices whose primary use is heating which include but are not limited to pellet stoves and inserts, corn stoves and inserts or any other device with emissions of 1 gram or less of particulate per hour, capable of being vented within 4 feet of an operable window and approved by the Building Official.

**Solid Fuel Heating Device (SFHD).** SFHD are those devices whose primary use is heating which include but are not limited to certain brands of wood stoves and inserts, and masonry heaters or any other device capable of controlling combustion through mechanical means and approved by the Building Official. *This definition shall specifically exclude fireplaces or barbeques.*

**Solid Fuel Decorative Device (SFDD).** SFDD are devices whose primary use is esthetic or decorative and shall include masonry or manufactured fireplaces or any other solid fuel, free burning device constantly open to view approved by the Building Official.

**505.3 Exhaust ducts. Delete Exception**

**505.7 Group I-1 occupancies delete exception**

**505.8 Group I-2 occupancies delete exception**

**508.1.1 Makeup air temperature.** Amend by adding the following: Exception. Seasonal operations open only during the months May through October do not have to provide **conditioned** makeup air.

Add section **701.3 Buildings of unusually tight construction**. Shall read: In all structures containing habitable space or unusually tight construction, combustion air shall be obtained from outside the thermal envelope.

Add section **901.5 Minimum Requirements**. Installation or relocation of a Solid Fuel Heating Device is prohibited unless the device meets the minimum requirements for Phase II emissions as established by the EPA at the time of its installation.

**Add section 901.6. Prohibited Installations:** Installation of Solid Fuel Heating Devices (SFHD) and/or Solid Fuel Decorative Devices (SFDD) is prohibited.

Exceptions:

1. A maximum of one SFHD may be installed in any detached single family dwelling.
2. A maximum of one SFDD may be installed in any detached single family dwelling. Properties a minimum of three acres in size may be permitted an additional SFDD and one additional SFDD for each additional acre in excess of three acres, up to a maximum of four SFDDs.
3. SFDDs shall be allowed for commercial developments when proposed to and approved by the Teton County, Board of County Commissioners as part of the Development Permit process.
4. Approved Solid Fuel Burning Devices (ASFBD) are exempt from the provisions of this section.

**903.3 Unvented gas log heaters.** Amend by adding the following sentence: Unvented gas log heaters shall not be installed in residential occupancies, habitable rooms or spaces or buildings of unusually tight construction.

## INTERNATIONAL FUEL GAS CODE AMENDMENTS

E. THE INTERNATIONAL FUEL GAS CODE 2024 IS SPECIFICALLY AMENDED AS FOLLOWS:

**101.1 Title.** Amend to read: These regulations shall be known as the Fuel Gas Code for Teton County, hereinafter referred to as “this code.”

Add section **101.1.1.** All references to “code official” in this code to shall mean Teton County, Building Official.

**108.2 Fee Schedule.** Amend to read: The fees for work shall be as indicated in the Schedule of Fees from the Teton County Planning & Building Services Department

**108.4 Work commencing before permit issuance.** Add a sentence to read: The permit fee shall be double.

**108.6 Refunds.** Amend to read as follows:

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of plan review fee payment, and then only under the following conditions:

1. The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.
2. The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.
3. The Building Official may authorize refunding of not more than 80 percent of the fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or cancelled before any plan review effort has been expended.

**Section 111.3.3 Reinspection and testing.** Reinspection and Testing as follows:

A reinspection fee may be assessed for the following circumstances:

For each reinspection that results from the applicant either not completing all or a portion of the work for which an inspection was previously requested; for not providing the approved plans to the inspector at the time of any inspection; for failure to provide access on the date and time for which the inspection is requested; for deviating from the plans without prior approval of the building official.

If assessed the applicant shall pay the reinspection fee as set forth in the Schedule of Fees from the Teton County Planning & Building Services Department. Depending on the circumstance additional work and/or inspections may be prohibited until reinspection fees have been paid and/or needed corrections have been completed.

**113.4 Violation penalties.** Amend to read: Persons, who shall violate a provision of this code, fail to comply with any of the requirements thereof or erect, install, alter or repair work in violation of the approved construction documents or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be subject to penalties as prescribed by law.

**Section 115, License required.** Add Section 115 License required as follows:

Contractors performing work requiring a permit under this code shall be licensed and have in their possession a contractor's license issued by the Town of Jackson, Wyoming.

Exceptions:

3. Owner(s) of a single family home performing work on their primary residence or associated outbuildings for their personal use. For purposes of this exception, homeowners who construct more than one house every two years in Teton County shall be considered contractors and shall be licensed.
4. Work being performed that does not require licensing by the Town of Jackson.

**303.3 Prohibited Locations.** Delete the following conditions to the exception; 3, 4.

**304.1 General.** Amend by adding the following as the first sentence: In all structures containing habitable space or unusually tight construction, combustion air shall be obtained from outside the building thermal envelope.

**403.3.3 Copper and copper alloy.** Revise the paragraph to read as follows: Copper piping shall not be used for gas piping systems.

**602.1 Decorative Appliances for Installation in Fireplaces.** Amend by adding the following sentence: Decorative appliances installed in residential occupancies shall be listed and labeled to operate with glass doors installed and in the closed position.

**Exception:** An approved Flue Sentinel may be installed with an electrical interlock in conjunction with the decorative appliance only if the doors are not installed on the fireplace.

**603.1 Log Lighters. General.** Add the following sentence: All gas fired log lighters shall be provided with a listed pilot safety device installed in accordance with the manufacturer's installation requirements.

## **621.2 Unvented room heaters. Delete section**

**621.4 Prohibited locations.** Amend by making the following the first sentence: Unvented gas log heaters shall not be installed in residential occupancies, habitable rooms or spaces, or buildings of unusually tight construction.

**621.6 Oxygen-depletion safety-system.** Add the following sentence: The room shall also be equipped with a listed Carbon Monoxide Detector installed according to the manufacturer's installation instructions.

**621.7 Unvented decorative room heaters.** Revise to read as follows: An unvented log heater shall not be installed in a factory-built fireplace unless the fireplace system has been specifically tested, listed and labeled for such use in accordance with UL 127 and Section 602.

## **621.7.1 Ventless firebox enclosures. Delete section**

# **INTERNATIONAL ENERGY CONSERVATION CODE**

F. THE INTERNATIONAL ENERGY CONSERVATION CODE 2021 IS AMENDED AS FOLLOWS:

**C101.1 Title.** Amend to read: These regulations shall be known as the Energy Conservation Code for Teton County, hereinafter referred to as "this code."

**C101.1.1.** All references to "code official" in this code to shall mean Teton County, Building Official.

**C402.5.1.5 Building envelope performance verification.** The first paragraph shall read; The installation of the continuous air barrier shall be verified by a registered design professional or approved

agency in accordance with the following and verification provided to the Building official prior to Certificate of Occupancy:

**N1101 (R401.1) GENERAL.** Amend by adding the following sections:

**Table R402.4.1.1.** Add Fireplace to read, Fireplaces shall be fitted with gasketed doors or the building shall pass a blower door test with the fireplace face open and the flue damper in the closed position.

**R402.1 Exception 2** shall read: In place of ICC400 Log buildings shall be provided with the following:

1. Exterior Log walls shall have a minimum diameter of 8 inches and shall be exempt from the exterior wall insulation requirements. Spiral cracks greater than  $\frac{1}{4}$  inch shall be sealed in an approved manner.
2. Roof/ceiling assemblies shall be provided with a minimum R060 insulation.
3. The reduction of R-values listed in N1102.2.1 and N1102.2.2 shall not apply.
4. All HVAC ductwork shall be insulated or installed within conditioned space.
5. The primary heating source shall have a minimum AFUE rating of 90.

**Add section R402.1.6 :** Finished Garages and Accessory Structures. Finished garages and accessory structures shall meet the minimum insulation requirements for Table R402.1

**R402.3** Amend by adding the following. Fenestration Limitation. Fenestration shall not exceed 30% of the gross conditioned wall area above grade. To determine allowable wall area of walk out (daylight) basements, the wall shall have a minimum of 6 foot exposure from finished grade.

Exception: The 30% limit can be exceeded if the designer can demonstrate that the UA total of the proposed design is less than the UA of the same structure with 30% fenestration total, and code minimum insulation and fenestration values by using the ResCheck or other approved software programs.

**Table R402.4.1.1.** Add Fireplace to read, Fireplaces must be fitted with gasketed doors or the building must pass a blower door test with the fireplace face open and the flue damper in the closed position.

**R402.4.1.2 Testing. Amend the fourth and fifth sentences to read;** Testing shall be conducted by an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official prior to certificate of occupancy.

**R403.3.5 Duct testing. Amend by adding at the end of the first sentence;** Testing shall be conducted by an approved third party or as approved by the code official.

## **INTERNATIONAL EXISTING BUILDING CODE**

**G. THE INTERNATIONAL EXISTING BUILDING CODE 2024 IS AMENDED AS FOLLOWS:**

**101.1 Title.** Amend to read: These regulations shall be known as the Existing Building Code for Teton County, hereinafter referred to as “this code.”

**101.1.1.** All references to “code official” in this code to shall mean Teton County, Building Official.

**108.2 Schedule of permit fees.** Amend to read as follows: The fee for building permits shall be as follows: Building Permit Fees will be established using the most current Building Valuation Data published by The International Code Council and a Permit Fee Multiplier as established in the Schedule of Fees from the Teton County Planning & Building Services Department. The multiplier and valuation for remodels and the minimum fees for building and miscellaneous permits shall also be as established in the Fee Schedule.

On structures requiring gas, mechanical or plumbing systems, a separate fee for each permit shall be accessed as required, in accordance with the Schedule of Fees from the Teton County Planning & Building Services Department. Electrical permit fees shall be determined by the Electrical Division of the Jackson Hole Fire/EMS Department.

Permit Fee Multipliers may be adjusted as deemed necessary under the direction of the Teton County Commissioners.

**108.2.1 Plan review fees.** Add Section 108.2.1 Schedule of permit fees. When submittal documents are required by Section 106.1, a Plan Review Fee shall be paid at the time of submitting the submittal documents for plan review. Said Plan Review Fee shall be 65 percent of the Building Permit Fee as shown in the Schedule of Fees from the Teton County Planning & Building Services Department.

The Plan Review Fees specified in this section are separate fees from the Permit Fees specified in section 108.2 and are in addition to the Permit Fees.

When submittal documents are incomplete or changed so as to require additional plan review or when the project involves deferred submittal items as defined in Section 106.3.4, an additional Plan Review Fee shall be charged at the rate shown in the Schedule of Fees from the Teton County Planning & Building Services Department.

**TABLE 1**

This TABLE sets forth projects which may require permit(s), if any, and identifies the specific type of permit(s) required and the site inclusion requirements. Additional permits not identified in Table 1 may also be required. It shall be the duty of the person and/or entity of a proposed project which is not specifically set forth in Table 1 to contact the Teton County Building Department for a determination of the type of permit(s) required, if any, and the site inclusion requirements.

**(1 ) BUILDING (2) PLUMBING (3) ELECTRICAL (4) MECHANICAL (5)GRADING  
(6) INDIVIDUAL SEWAGE DISPOSAL (7) SIGN (8) MANUFACTURED HOUSING  
HOOKUP (9) FIRE ALARM SYSTEM (10) FIRE SPRINKLER SYSTEM ROUTING**

**ABBREVIATION:**

**BUILDING DIVISION=BD      ENVIRONMENTAL HEALTH=EH  
PLANNING DIVISION=PD      ENGINEERING=EG      FIRE=FD**

(This Table is a Permit Requirement Guideline ONLY, and does not take precedence over the Teton County Land Use Regulations or the International Codes as adopted by Teton County)

<b>CLASSIFICATION OF PROJECTS</b>	<b>SPECIFIC PROJECTS</b>	<b>NO PERMIT REQUIRED</b>	<b>PERMIT (S) REQUIRED</b>	<b>REVIEW REQUIRED</b>	<b>SITE PLAN REQUIRED</b>
<b>New Structures &amp; Factory Built Structures &amp; Manufactured on Private Land</b>	Building of New Residential Structures		1,2,3,4,5,6,9,10	BD,PD,EG, FD	X
	Building of New Non-Residential Commercial Structure		1,2,3,4,5,6,9,10	BD,EH,PD,EG, FD	X
	Moving of Existing Structure to New Location		1	BD,EH,PD,EG FD	X
	Moving of Manufactured Housing into a Mobile Home Park		3,8	BD,PD	X
	Moving & Setting of Factory Built Structure on Building Site		1,2,3,4,5,6	BD,EH,PD,EG	X
	May Require a Road Cut Permit Through Engineering Department		5	EG	X
<b>Amended Agricultural</b>	Building of a Structure Used Solely as an Agricultural Building (See 105.2 Item 14 )	X		PD	X
	One story detached buildings used as tool and storage sheds playhouses and similar uses provided the projected roof area does not exceed 200 s.f.	X		PD	X
<b>Condemned Buildings</b>	Demolition of the Whole or Part of Building, Factory Built Structures, or Manufactured Housing		1	BD,PD	
<b>Additions &amp; Alterations to Exterior Construction &amp; On Site Accessory Construction</b>	Additions & alterations involving bedroom, bathroom, kitchen, living room, or other accessory rooms		1,2,3,4,6,9,10	BD,EH,PD,EG	X
	Additions & alterations involving an attached or detached garage or shop		1,2,3,4,5,6	BD,PD,EG	X
	Non-structural sidewalks/slabs	X			

CLASSIFICATION OF PROJECTS	SPECIFIC PROJECTS	NO PERMIT REQUIRED	PERMIT (S) REQUIRED	REVIEW REQUIRED	SITE PLAN REQUIRED
Additions & Exterior Construction & On Site Accessory Construction	Decks & Patios not over 30 inches above grade with no permanent construction above the floor line	X		PD	X
	Decks, Entry Porches, Etc.		1,3	BD,PD	X
	Retaining Walls, over 4 feet in height (Engineering Required)		1	BD,EG	X
	Fences over 6 feet in height		1	BD,PD	X
	Fences used for Agricultural purposes only or those fences under 6 feet in height	X			
	Erection of Exterior Signs (Except as Exempt in Zoning Resolutions)		7	BD,PD	X
	All Non-Structural Landscaping	X			
Demolition	Removal of any structure		X	BD,PD,FD*	X
Exterior Repair & Replacement &/or Addition	Replacement of Roof		1	BD	
	Repair of Replacement of Exterior Siding	X			
	Addition of Exterior Window		1	BD	
	Repair of Existing Exterior Window	X			
	Addition of Exterior Door		1	BD,PD	
	Repair or Replacement of Existing Exterior Door	X			
Interior Repair & Replacement &/or Addition	Repair or Replacement of floor covering	X			
	Painting, Papering or Similar Finish Work-Exterior or Interior	X			
	Installation of Wood burning Stove or Fireplace		4	BD	

\* May be approved over-the-counter with proper documentation.

SECTION 8. REPEAL. Upon the approval and adoption of this Resolution by the Teton County Board of Commissioners, all existing or previously adopted Building Resolutions not reflected in this Resolution be and the same are hereby repealed and superseded by this Resolution.

SECTION 9. SEVERABILITY. The Teton County Board of Commissioners hereby declares that if any section, subsection, clause or phrase of this Resolution or of the 2024 International Codes and the 2021 International Energy Conservation Code adopted by this Resolution, is for any reason held to be invalid by the decision of any court of competent jurisdiction, such decision shall not affect the validity of the remaining portions of this Resolution and/or the 2024 Codes and the 2021 International Energy Conservation Code.

PASSED, APPROVED AND ADOPTED on June 17, 2025, and effective upon July 1, 2025.

ATTEST:

  
Maureen Murphy

County Clerk



TETON COUNTY

  
Mark Newcomb  
Chairman, County  
Commissioners