



Required Items to be on Electrical Plan Reviews

1. State job address, building permit number (if one currently), occupancy use, NEC code year.
2. Service or feeder Load calculations for new/remodel/addition, with new/remodel/addition one line(s).
3. Electrical Panel(s) locations, voltage, phase, and fault current calculated values.
4. Panel Schedules shall meet Art 408.4A & B, i.e. locations, use, descriptive, No Abbreviations.
5. Electrical service load calculations to meet Art 220 Part 3 or Part 4.
6. Grounding detail and location of grounding electrode system, as amended by Teton County Wyoming.
7. Show all locations of receptacles, lighting, mechanical equipment, utilization equipment, processing equipment, all other equipment, appliances, plus access and workspace requirements Art 110.26.
8. Complete circuiting of all receptacles, lighting, mechanical equipment, utilization equipment, processing equipment, all other equipment, and appliances.
9. Show all exit signs and emergency lighting if required to meet Art. 700.
10. Indicate on plans, (tenants) have access to all overcurrent devices. Art 230.72 & 210.25A & B
11. If there are common areas, a common house panel shall be required for all common area power. The house panel shall be in a common area accessible to all occupants. Common equipment shall be in common areas. Art 230.72 & 210.25B
12. Show locations of all special devices: AFCI, GFCI, EPD, etc.
13. State any Special Occupancies. Chapters 5-7, i.e. (Pools/Hot Tubs) or hazardous locations.
14. State any Special Equipment. Chapter 5-7 i.e., Generator, PV Solar Systems, Energy Storage Systems, Batteries, etc.
15. Show location and type of Smoke Detectors. (Residential Only)

Please contact the Chief Electrical Inspector if you have any questions at 307-733-4732.

****Items are not all inclusive, depending on scope of the project****